

Dowville Tract Hydrant Test Record

Test Date	6/14/2017
Time	11:00
Tip Size:	1 - 3/4"

Name of tester(s)	L. Linnman, S. Linmann, P. Allbright
	C. Donnelly, Chief 62

All hydrants have a single 2 1/2" Fire hose connection

Hydrant Number	Water Main Size	Location	Color of Hydrant Top	<i>BEFORE Flowing Water</i>		<i>WHILE Water is Flowing</i>			
				Static reading on test hydrant	Static reading on remote hydrant	Residual reading on test hydrant	Residual reading on remote hydrant	Pitot reading	GPM From chart 1 - 3/4" tip
1	4"	Cabin 88 - Top of Dowville East	Red	61	120	n/a	75	7	243
2	4"	Cabin 47 - Peter Knapp	Red	120	61	n/a	28	12	308
3	4"	Cabin 72 - Glenn Johnson	Red	72	92	n/a	62	7	243
4	4"	Cabin 54 - Bates	Red	98	92	n/a	90	12	308
5	4"	Cabin 18 - Conway	Red	92	120	n/a	75	8	256

Hydrant Color Coding : Blue= 1500+ gpm; Green = 1,000 - 1499 gpm; Orange = 500 - 999 gpm; Red = Below 500 gpm