

Huntington Pines Fire Hydrant Test Record

Test Date	9/15/2017		Name of tester(s)	P. Allbright; L. Coleman
Time	9:30		F. Wienholz; C. Donnelly, Chief 62	
Tip Size:	2 - 1/2"			
Hydrant Types:	D = Dresser 500; M5 = Mueller 5 1/4 (both have 1-4.5" Steamer and 2- 2.5") M2.5 = Mueller with 1 - 2.5"			

Hydrant #	Water Main Size	Location	Hydrant Type & Color	<i>BEFORE Flowing Water</i>		<i>WHILE Water is Flowing</i>			
				Static reading on test hydrant	Static reading on remote hydrant	Residual reading on test hydrant	Residual reading on remote hydrant	Pitot reading	GPM From chart 2 - 1/2" tip
1	6"	base of water tank -south	D-Orange	23	41	20	36	10	533
2	6"	base of water tank - north	D-Orange	23	41	20	36	10	533
3	6"	H.Vista & Regatta Vista	M5-Orange	34	34	38	26	14	631
4	6"	Condo 48 - R.V. # 10 (Eggbratten house)	M5-Orange	38	38	30	34	16	675
5	6"	Condo 40 - H. Vista (near old tank)	D-Orange	46	46	34	42	22	791
6	6"	Condo 29 - H. Vista & Sunny Vista	D-Orange	46	60	22	48	11	559
7	6"	Condo 119 - H. Vista @ Ski View	D-Orange	OTS		OTS			
8	6"	Condo 103 - Ski View - West	D-Orange	70	46	40	44	24	826
9	6"	Condo 96 Ski View - East	D-Orange	60	46	32	44	20	754
10	6"	Condo 111 - Huntington Vista	D-Orange	82	60	31	42	18	716
11	6"	Condo 3 - Hidden Springs	D-Orange	82	60	62	42	20	754
12	6"	Condo 110 - H. Vista & Meadow View	D-Orange	102	100	40	74	18	716
13	6"	Fire House - at the gate	M2.5-Orange	120	102	n/a	75	10	533
14	6"	Condo 12 - Old College	D-Orange	102	92	40	84	23	809
15	6"	Swim Pool - Sunny View	D-Orange	92	66	37	50	16	675

Note: Hydrant 7 is out of service

Hydrant Color Coding : Blue= 1500+ gpm; Green = 1,000 - 1499 gpm; Orange = 500 - 999 gpm; Red = Below 500 gpm