

Huntington Pines Fire Hydrant Test Record

Test Date	6/21/2021		Name of tester(s)	R. Baker; K. Kirkman; J. Henderson
Time	11:00		F. Wienholz; C. Donnelly, Chief 62 (HLVFD)	
Tip Size:	2 - 1/2"			
Hydrant Types:	D = Dresser 500; M5 = Mueller 5 1/4 (both have 1-4.5" Steamer and 2- 2.5") M2.5 = Mueller with 1 - 2.5"			

Hydrant #	Water Main Size	Location	Hydrant Type & Color	<i>BEFORE Flowing Water</i>		<i>WHILE Water is Flowing</i>			
				Static reading on test hydrant	Static reading on remote hydrant	Residual reading on test hydrant	Residual reading on remote hydrant	Pitot reading	GPM From chart 2 - 1/2" tip
1	6"	base of water tank -south	D-Orange	24	24	21	36	10	533
2	6"	base of water tank - north	D-Orange	24	42	21	36	11	559
3	6"	H.Vista & Regatta Vista	M5-Orange	42	44	38	37	18	716
4	6"	Condo 48 - R.V. # 10 (Eggbratten house)	M5-Orange	44	46	38	42	21	773
5	6"	Condo 40 - H. Vista (near old tank)	D-Orange	46	69	30	38	23	809
6	6"	Condo 29 - H. Vista & Sunny Vista	D-Orange	69	42	22	32	15	653
7	6"	Condo 119 - H. Vista @ Ski View	D-Orange	OTS		OTS			
8	6"	Condo 103 - Ski View - West	D-Orange	42	50	42	39	24	826
9	6"	Condo 96 Ski View - East	D-Orange	50	78	32	65	20	754
10	6"	Condo 111 - Huntington Vista	D-Orange	78	88	34	52	16	675
11	6"	Condo 3 - Hidden Springs	D-Orange	88	100	50	56	25	843
12	6"	Condo 110 - H. Vista & Meadow View	D-Orange	100	119	44	62	16	675
13	6"	Fire House - at the gate	M2.5-Orange	119	100	n/a	70	25	843
14	6"	Condo 12 - Old College	D-Orange	100	92	46	41	20	773
15	6"	Swim Pool - Sunny View	D-Orange	92	100	42	74	23	809

Note: Hydrant 7 is out of service and several remote hydrants changed locations

Hydrant Color Coding : Blue= 1500+ gpm; Green = 1,000 - 1499 gpm; Orange = 500 - 999 gpm; Red = Below 500 gpm